



# Climate change impacts on solar power generation and its spatial variability in Europe based on CMIP6

Xinyuan Hou<sup>1,2</sup>, Martin Wild<sup>1</sup>, Doris Folini<sup>1</sup>, Stelios Kazadzis<sup>2</sup>, Jan Wohland<sup>3</sup>

<sup>1</sup>Institute for Atmospheric and Climate Science, ETH Zurich, 8006, Switzerland

<sup>2</sup>Physikalisch-Meteorologisches Observatorium Davos/World Radiation Center, 7260, Switzerland

<sup>3</sup>Institute for Environmental Decisions, ETH Zurich, 8006, Switzerland

*Correspondence to:* Xinyuan Hou (xinyuan.hou@pmodwrc.ch)

**Abstract.** Solar photovoltaics (PV) plays an essential role in decarbonizing the European energy system. However, climate change affects surface solar radiation and thereby will directly influence future PV power generation. We use scenarios from the sixth phase of the Coupled Model Intercomparison Project (CMIP6) for a mitigation (SSP1-2.6) and a fossil-fuel dependent (SSP5-8.5) pathway, to quantify climate risk for solar PV in Europe simulated by the Global Solar Energy Estimator (GSEE). We find that PV potential increases by around 5% in the mitigation scenario, suggesting a positive feedback loop between climate change mitigation and PV potential. While increased clear-sky radiation and reduced cloud cover go hand in hand in SSP1-2.6, a decrease in clear-sky radiation is overcompensated by a decrease in cloud cover in SSP5-8.5, resulting in an increase of all-sky radiation. Moreover, we find that the seasonal cycle of PV generation changes in most places as generation grows more strongly in winter than in summer (SSP1-2.6) or increases in summer and declines in winter (SSP5-8.5). We further analyze climate change impacts on the spatial variability of PV power generation. Similar to effects anticipated for wind energy, we report an increase of the spatial correlations of daily PV production with large inter-model agreement yet relatively small amplitude, implying that PV power balancing between different regions in continental Europe will become more difficult in the future. Based on the most recent climate simulations, this research thus supports the notion that climate change will only marginally impact renewable energy potential, while changes in the spatio-temporal generation structure are to be expected and should be included in power system design.

## 1 Introduction

To combat climate change, humankind has to drastically reduce carbon emissions in the coming decades (IPCC, 2013). Solar photovoltaics (PV) are a key technology to achieve this goal because the potential of PV exceeds current electricity demand (Tröndle et al., 2019) and its costs have plummeted over the last years (Creutzig et al., 2017; IRENA, 2019). As of today, the global installed PV capacity amounts to 580 GW, reflecting a 20-fold increase since 2010, as reported by the International Renewable Energy Agency (IRENA, 2020). Within less than three decades, the European Union (EU) wants to achieve net



30 carbon neutrality (EU, 2019). This ambitious timeline implies accelerated deployment of renewable generation technology, dominantly wind and solar power. In the short run by 2030, the EU aims at about 30% renewables in energy consumption.

Power generation from sunlight is weather dependent and thus fluctuates in space and time (e.g., Bloomfield et al., 2021; van der Wiel et al., 2019). In a power system, these fluctuations can be mainly mitigated through (a) large-scale interconnection that averages spatially over different weather conditions (e.g., Rodriguez et al., 2014; Grams et al., 2017; Bremen, 2010), (b) electricity storage that averages temporally over different weather conditions (e.g., Kittner et al., 2017), and (c) optimized  
35 portfolios that exploit synergies between different types of generation (e.g., Heide et al., 2010). Weather and climate variability govern the extent to which these options can be successful – now and in the future. Future PV power generation, in particular, is linked to atmospheric parameters that affect surface solar radiation such as cloud coverage and optical thickness, aerosols, and water vapor.

Earlier studies have investigated impacts of climate change on surface radiation and PV power production under different  
40 climate scenarios, generally finding limited magnitudes of changes in solar potential (Wild et al., 2015; Jerez et al., 2015; Panagea et al., 2014; Gaetani et al., 2014; Crook et al., 2011). These assessments were mostly based on data from the Climate Modeling Intercomparison Project Phase 5 (CMIP5, Taylor et al., 2012) or the Coordinated Downscaling Experiment (EURO-CORDEX, Jacob et al., 2014).

However, recent evidence suggests that most EURO-CORDEX models are poorly suited to investigate surface solar radiation  
45 because aerosols were kept constant in the regional climate models used for the downscaling (Gutierrez et al., 2020, Bartock et al. 2017). Some earlier studies based on regional climate models therefore have to be interpreted with caution. Moreover, most studies focus on long-term averages of power generation and neglect changes in the spatio-temporal structure of PV generation. However, ignoring changes in the spatio-temporal structure, induces a risk in power system design. For instance,  
50 Wohland et al. (2017) reported that wind power generation will become more uniform over Europe; thus, more countries will experience below-average wind generation at the same time, thereby reducing the potential to smooth generation variability by spatial integration. It remains to be evaluated whether similar effects exist for solar PV.

This study therefore has two goals:

- First, we test the robustness of earlier results by evaluating changes in surface solar radiation and PV potentials in  
55 Europe based on the sixth phase of the Coupled Model Intercomparison Project (CMIP6, Eyring et al., 2016). To this end, we use projections from 28 CMIP6 models to account for model uncertainty and consider pathways at the upper and lower end of mitigation ambition to cover the range of different potential futures (SSP1-2.6, SSP5-8.5).
- To assess risks for the power system that stem from changes in the spatio-temporal structure of PV generation, we



60 analyze climate change impacts beyond the long-term mean. In particular, we quantify changes in spatial correlations  
of PV power generation over the continent and analyze balancing potentials between different focus regions in  
continental Europe.

## 2 Data and methods

### 2.1 CMIP6 data

65 We use the output from 28 CMIP6 models in daily and monthly resolution (see Table 1). In the assessment of the climate  
variables, we use conservatively remapped monthly data aligned with the lowest model resolution ( $2.5^\circ \times 2.5^\circ$ ). By contrast, to  
account for the non-linear dependency of PV generation on climatic inputs, we run the PV model with daily data in the finer  
original spatial resolution. PV generation is thus calculated on a different grid for each climate model. To ease inter-model  
comparison, the PV generation is subsequently remapped onto the uniform  $2.5^\circ \times 2.5^\circ$  grid. Unless otherwise stated, we  
selected the r1 ensemble member from each model, where there might be multiple members available.

70 To evaluate the operating conditions of solar PV, we analyzed four climate variables: surface downwelling shortwave radiation  
under all-sky conditions (rsds), surface temperature (tas), surface downwelling shortwave radiation under clear-sky conditions  
(rsdscs) and total cloud fraction (clt). Surface downwelling radiation is the fuel of a solar cell and the surface temperature  
influences the panel efficiency. Clear-sky radiation and cloud fraction allow to contextualize changes in all-sky radiation. All-  
sky radiation is affected by cloud cover and atmospheric composition (e.g. aerosol load), while the clear-sky component  
75 considers only changes due to atmospheric composition and assumes cloud-free conditions.

We analyze two climate change scenarios: the Shared Socioeconomic Pathways (SSPs) 1-2.6 and 5-8.5, representing the low  
and high end of the range of the mitigation challenges (O'Neill et al., 2016). SSP1 envisions sustainable development and  
stringent climate change mitigation, while SSP5 assumes continued heavy reliance on fossil fuels. The associated numbers 2.6  
and 8.5 indicate the radiative forcing in  $\text{W m}^{-2}$  by the year 2100 compared to the pre-industrial period 1850 - 1900 according  
80 to the United Nations Framework Convention on Climate Change (UNFCCC, 2015). Broadly speaking, SSP1-2.6 is the  
successor of the Representative Concentration Pathway (RCP) 2.6 while SSP5-8.5 replaces RCP8.5. We compare the climate  
variables' multi-model mean of the period 2081 - 2100 to the reference historical time span 1995 - 2014. We measure the inter-  
model agreement by the number of models showing the same sign of change and consider the agreement to be high if more  
than 75 % agree.

85 **Table 1:** CMIP6 models used in this study, with the institution, model acronym, and horizontal grid resolution (number of grid  
points). Output from all these 28 models is available in monthly and daily resolution.



Institution	Model acronym	Lon.	Lat.
CSIRO (Commonwealth Scientific and Industrial Research Organisation) & Bureau of Meteorology, Australia	ACCESS-CM2	192	144
	ACCESS-ESM1-5	192	145
Beijing Climate Center, China Meteorological Administration	BCC-CSM2-MR	384	192
National Center for Atmospheric Research (NCAR)	CESM2	288	192
	CESM2-WACCM	288	192
Centro Euro-Mediterraneo per I Cambiamenti Climatici	CMCC-CM2-SR5	288	192
Centre National de Recherches Meteorologiques	CNRM-CM6-1	720	360
	CNRM-CM6-1-HR	256	128
	CNRM-ESM2-1	256	128
EC-EARTH consortium	EC-Earth3 <sup>a</sup>	512	256
	EC-Earth3-Veg <sup>a</sup>	512	256
Institute of Atmospheric Physics, Chinese Academy of Sciences	FGOALS-g3	180	80
Geophysical Fluid Dynamics Laboratory	GFDL-ESM4	288	180
Met Office Hadley Centre	HadGEM3-GC31-LL	192	144
	HadGEM3-GC31-MM	432	324
Institute for Numerical Mathematics	INM-CM4-8	180	120
	INM-CM5-0	180	120
Institut Pierre-Simon Laplace	IPSL-CM6A-LR	144	143
National Institute of Meteorological Sciences / Korea Met. Administration	KACE-1-0-G	192	144
Korea Institute of Ocean Science & Technology	KIOST-ESM	192	96



---

Japan Agency for Marine-Earth Science and Technology, Atmosphere and Ocean Research Institute (The University of Tokyo) & National Institute for Environmental Studies	MIROC6	256	128
Max Planck Institute for Meteorology (MPI-M)	MPI-ESM1-2-HR	384	192
	MPI-ESM1-2-LR	192	96
Meteorological Research Institute	MRI-ESM2-0	320	160
Nanjing University of Information Science and Technology	NESM3	192	96
Norwegian Climate Centre	NorESM2-LM <sup>b</sup>	144	96
	NorESM2-MM	288	192
Met Office Hadley Center (MOHC)	UKESM1-0-LL	192	144

---

a: does not provide clear-sky surface downwelling shortwave radiation (rsdscs).

b: does not provide cloud fraction (clt) in SSP5-8.5.

## 2.2 Modeling solar photovoltaics

90 Based on the aforementioned climate variables, we calculate solar power generation using the Global Solar Energy Estimator (GSEE, Pfenninger and Staffell, 2016). GSEE allows us to simulate PV electricity production of a solar panel on annual to hourly intervals (Müller et al., 2019). Here, we use the highest temporal CMIP6 output resolution (daily data) to also capture changes in the distributions and spatial correlations of daily PV production. This approach particularly reflects the non-linear relation between climatic inputs and GSEE derived PV generation.

95 For the calculations, we adopt the prevailing PV technology using crystalline silicon (IRENA, 2019). Inputs to GSEE include total horizontal irradiance (sum of direct and diffuse radiation, here rsds from CMIP6), the fraction of diffuse irradiance from total horizontal irradiance (using the Boland–Ridley–Lauret model in Ridley et al., 2010; pre-defined in the GSEE software module), the ambient temperature (tas from CMIP6), and panel-specific parameters (grid coordinates, tilt and azimuth angle, peak generation capacity, panel tracking mode). We compute the optimal tilt angle in degrees for each latitude using linear  
100 regression after Jacobson and Jadhav (2018) and use an azimuth angle of 180° (facing south towards the equator). A capacity of one kilowatt per grid cell is used with fixed panels (no sun-tracking).

The focus on Europe translates into a rectangular geo-grid extended from 10° W to 30° E and 35 to 75° N. The PV output data from the GSEE are remapped to a spatial lon×lat resolution of 2.5°×2.5° using the first-order conservative remapping, leading to a common grid of 16×16 cells.



## 105 2.3 Seasonal analysis approach

We analyze summer (June, July and August) and winter (December, January and February) changes separately to investigate potential impacts on the seasonal cycle and to highlight intra-annual variations that could be masked in annual means. Both wind and solar generation follow strong seasonal cycles in Europe and have their maximum generation in different parts of the year; PV peaks in summer whereas wind power peaks in autumn. The evolution of the seasonal cycle is of high practical  
110 relevance, as combining wind and solar power allows smoothing generation variability throughout the year (Heide et al., 2010). Optimal shares of wind and solar power would thus change if the seasonal cycle of generation changes.

When investigating correlation changes in PV production, we remove the seasonal cycle over the reference period (1995 - 2004) by subtracting the 20-year daily mean, and dividing by the 20-year daily standard deviation:

$$PV_{d, des} = \frac{PV_d - \overline{PV_{d, ref\ 20yr}}}{\sigma(PV_{d, ref\ 20yr})}, \quad (1)$$

115 For instance, deseasonalized PV production on 01.02.2085 is computed as PV generation on that day minus mean PV production on 01.02. from 1995 to 2014, divided by the standard deviation on 01.02. throughout the reference 20 years. This procedure delivers excess or deficit in daily PV production from its long-term average during the reference period and captures changes in the seasonal cycle.

## 2.4 Spatial correlation methodology

120 We conduct a correlation analysis on daily PV generation from two different 20-year periods (1995 - 2014 from the historical CMIP6 simulations, and 2081 - 2100 from the SSP1-2.6 and the SSP5-8.5 scenarios, respectively) following the approach in Wohland et al. (2017) to identify changes in the spatial PV generation patterns. For each CMIP6 model, we compute a matrix of correlations, each matrix entry corresponding to one of the 16×16 grid boxes covering Europe. Each grid point (matrix entry) is assigned the average Pearson correlation between itself and all other grid points. If this value is high, the grid point  
125 is – on average – highly correlated to all other grid boxes in the domain. If it is close to zero, the grid point is – on average – largely uncorrelated to the other grid boxes. This approach yields one correlation matrix of the 16×16 dimensions for each of the three 20-year periods.

We characterize the long-term changes in spatial variability by correlation changes between 2081 - 2100 and 1995 - 2014:

$$\Delta Corr_{SSPi} = Corr_{SSPi} - Corr_{his}, \quad (2)$$

130 where  $Corr_{SSPi}$  stands for the correlation matrix in the SSP1-2.6 and SSP5-8.5 scenarios, respectively, and  $Corr_{his}$  for the historical run. Finally, we iterate the procedure for each model and compute the multi-model mean of  $\Delta Corr_{SSPi}$  from all 28 models.



## 2.5 Case studies

135 While the correlation analysis enables the comparison of continental-scale changes, it fails to capture smaller-scale features  
due to the averaging procedure. To overcome this limitation, we investigate three case studies, namely the Iberian ( $10^{\circ}$  W- $0^{\circ}$ ,  
35- $42.5^{\circ}$  N) and the Balkan ( $0^{\circ}$  W- $30^{\circ}$  E, 35- $42.5^{\circ}$  N) peninsulas, as well as central Europe ( $5$ - $15^{\circ}$  E,  $45$ - $50^{\circ}$  N) by lon-lat  
boxes. The atmospheric conditions over these regions are subject to the general atmospheric circulation patterns over the  
European continent, but they are sufficiently far separated to experience different weather conditions simultaneously. Central  
Europe has a high share of the electricity load in the European continent (Wohland et al., 2017). Located in southern Europe,  
140 Iberia and the Balkans are rich in solar resources and possess a high potential for PV electricity production. They are also  
connected within the European power grid network, providing high potential for energy balancing. We aggregate daily PV  
generation over the respective area and then compute correlations between deseasonalized daily time series (see Sect. 2.3)  
from the different areas to examine their mutual power generation balancing potential.

## 3 Results

145 In this section, we first calculate the projected changes of four climate variables: all-sky radiation (rsds) as the key parameter  
governing PV production, clear-sky radiation (rsdscs) and cloud fraction (clt) to differentiate between clouds and other factors  
affecting rsds, and surface temperature (tas) to illustrate future warming in Europe as another parameter affecting PV  
production (Sect. 3.1). We show that changes in all-sky radiation and their underlying causes in terms of cloud fraction and  
clear-sky radiation depend on the scenario (SSP1-2.6 or SSP5-8.5) and the season (summer or winter). Next, we proceed to  
150 implied changes in PV production in absolute ( $\text{Wh d}^{-1}$ ) and relative (%) terms (Sect. 3.2). Associated findings for SSP5-8.5  
are found to be largely in line with corresponding studies based on RCP8.5 from CMIP5 (Müller et al. 2019). For SSP1-2.6,  
we find qualitatively different results that to our knowledge are original and have no CMIP5 counterpart in the literature.  
Finally, we turn from mean power production to spatio-temporal balancing of PV power production. Looking at spatial  
correlations of daily PV power production under present-day and future projections, we find that the balancing potential among  
155 European regions tends to decrease in the future (Sect. 3.3).

### 3.1 Projected climate changes


In the annual mean, Europe is projected to become warmer and have higher all-sky radiation available in both scenarios (see  
Figs. 1 & 2). Exceptions are Iceland and parts of Scandinavia, but the model agreement there is lower. In line with expectations,  
temperatures rise in both climate change scenarios and the increase is nearly twice as strong in SSP5-8.5 compared to SSP1-  
160 2.6. All-sky radiation, however, evolves differently in the two scenarios. In SSP1-2.6, a decrease of up to 4 % in cloud cover  
and an increase in clear-sky radiation (fewer aerosols) jointly contribute to the increase of 5 - 10  $\text{W m}^{-2}$  in all-sky radiation  
(Fig. 1). In contrast, the increase in SSP5-8.5 all-sky radiation results from a decrease of up to 10 % in cloud cover, despite a  
decrease of 3 - 5  $\text{W m}^{-2}$  in clear-sky radiation (Fig. 2). We attribute this discrepancy in the evolution of clear-sky radiation to



165 competing effects from future warming, associated changes in atmospheric water vapor, and projected future aerosol emissions  
in SSP1-2.6 and SSP5-8.5. The stronger warming in SSP5-8.5 results in a higher atmospheric water vapor content, thus  
stronger short-wave absorption and decreased (clear-sky) radiation. Future anthropogenic aerosol emissions are projected to  
decrease in both scenarios, implying an increase in clear-sky radiation, but the projected decrease occurs earlier and is stronger  
under SSP1-2.6 (Gidden et al. 2019). In SSP1-2.6, the strong reduction in aerosols dominates over the weak increase in water  
vapor, resulting in an overall increase of clear-sky radiation, while for SSP5-8.5 the strong warming and increase in water  
170 vapor dominate.

The seasonal breakdown reveals different evolutions in summer and winter. In summer, the patterns for all four variables and  
both scenarios strongly resemble the annual means. In winter, however, the pattern of all-sky radiation changes in SSP5-8.5 is  
qualitatively different, with decreasing radiation in most of Europe except around the Mediterranean. There is a major increase  
of up to  $10 \text{ W m}^{-2}$  in southern Europe, but northwards all-sky radiation mainly decreases. Looking again separately at clear-  
175 sky radiation and cloud cover suggests the latter to play a key role for the qualitatively different winter pattern, although the  
model agreement is limited.





**Figure 1:** Change in climate variables relevant for PV production in SSP1-2.6. Maps show differences between 2081-2100 and 1995-2014 in the multi-model mean, calculated as future minus reference. Each row shows one variable and each column refers to one period of interest. The variables are in descending order: (a) - (c): temperature above surface (tas), (d) - (f): surface downward solar radiation (rsds), (g) - (i): surface downward clear-sky solar radiation (rsdscs), (j) - (l): total cloud fraction (clt). The left column depicts the mean over the entire year, whereas summer (June, July and August) and winter (December, January and February) are displayed in the other columns. The same variables share color bars of the same limits. The dots signify less than 75% model agreement in the sign of the projected changes.

180



185 In summer, we observe slightly stronger warming than in winter in both SSP scenarios. For SSP5-8.5, the temperature increases in northern regions are higher than in the south in winter, whereas in summer the reverse is true. The summer increase in all-sky radiation is more pronounced in SSP5-8.5 than in SSP1-2.6. For SSP5-8.5, summer cloud fraction changes reach >10% decreases, resulting in increases of up to  $25 \text{ W m}^{-2}$  in all-sky radiation, while clear-sky radiation changes are in the order of 0 to  $-5 \text{ W m}^{-2}$ .

190 In addition to the opposite sign of changes in clear-sky radiation, the model agreement also varies greatly for each scenario. While the model agreement of clear-sky radiation is high in SSP1-2.6, fewer models agree on the sign of changes in SSP5-8.5. The low agreement affects eastern Europe in summer and the majority of the continent in winter. In SSP5-8.5, the disagreement in winter cloud fraction is mainly in central and northern Europe, also in northwestern Iberia.

The evolution of cloud cover is remarkably similar in all scenarios. A large-scale decline in the order of 5% occurs in summer in both scenarios and causes a negative change in the annual mean. The annual mean, however, is weaker and less robust due to the mostly uncertain and weak changes in winter. Given the strong seasonality of radiation, the summer decline in cloud cover is of greater relevance for mean PV generation than the winter increase.





Figure 2: Change in climate variables relevant for PV production in SSP5-8.5. The figure is structured in the same way as Fig. 1.



### 3.2 Simulated PV electricity production

We now report projected changes for PV power generation. Figures 3 and 4 show the multi-model mean absolute change and relative change of PV electricity projection from the historical period to the SSP1-2.6 and SSP5-8.5 scenarios, respectively. The overall absolute and relative change patterns in PV electricity production are similar within their scenario and closely follow the patterns of change in all-sky radiation ((d) - (f) in Fig. 1 and Fig. 2), as expected. The changes in both seasons vary with latitude in both SSP scenarios.

For SSP1-2.6, positive changes in PV yields dominate in continental Europe (Fig. 1). Prominent absolute changes in summer include a strong increase in central Europe, while the Mediterranean region features only a slight increase. The latitudinal pattern is qualitatively reversed in winter, with the strongest overall increase in PV electricity generation around the Mediterranean. In particular, there is a substantial increase in the Apennine and Balkan Peninsulas in winter, whereas west- and northwards, the signal is much weaker. Besides, negative changes of small absolute magnitude and with low model agreement occur in northern Scandinavia.





215 **Figure 3: Impacts of climate change on PV generation in SSP1-2.6. Multi-model annual (left), summer (June, July and August; middle) and winter (December, January and February; right) (a) - (c): mean absolute change ( $\text{Wh d}^{-1}$ ) and (d) - (f): relative change (%) of simulated PV electricity generation between the period 2081-2100 and the period 1995-2014. The dots signify less than 75% model agreement in the sign of the projected changes.**

220 In the strong climate change scenario SSP5-8.5, the annual mean generation increases over most of the European continent. The hot spots of summer increase in absolute terms are centered in Germany and countries in the same or higher latitudes, such as Poland and the Czech Republic. In the south of Iberia, Italy and the Balkans, PV yields decrease. During winter, the opposite changes hold.

225 While the strongest summer increase is found in central to northern Europe, the strongest winter increase occurs in the South. This feature occurs similarly in both scenarios. The practical relevance of the decrease in the northernmost part of the domain is limited because high latitudes are barely suitable for large-scale PV electricity production due to limited solar radiation reaching the surface there.

230 To conclude, we find that mitigating emissions according to the SSP1-2.6 improves the climatic boundary conditions for PV and would lead to approximately 5% more power generation compared to today. Moreover, the seasonal cycle of PV generation is expected to become more pronounced as the generation grows stronger in summer than in winter (SSP1-2.6) or grows in summer and decreases in winter (SSP5-8.5). The southern end of the continent represents an exception, as summer generation decreases while winter generation increases in SSP5-8.5.







Figure 4: Impacts of climate change on PV generation in SSP5-8.5. The figure is structured as Fig. 3.



### 3.3 Correlation changes of PV electricity production

Future carbon-free power systems need to reliably provide electricity despite the variability of renewable power generation.

235 One key strategy in this context is inter-country transmission, which allows to exploit the complementarity of generation in  
different countries. Unfortunately, we find that PV generation becomes more uniform in both SSP scenarios; the change in  
correlation is positive virtually everywhere (Fig. 5). Moreover, the signal is approximately twice as strong in SSP5-8.5  
compared to SSP1-2.6, suggesting that the correlation increases with forcing. This finding is robust across the set of models  
as the inter-model agreement is high: more than three-quarters of all models show the same sign of change except for a few  
240 grid boxes towards the margins of the continent (northern Britain and Norway for both SSP scenarios and in the southern  
margin of Europe for SSP1-2.6). For SSP5-8.5, the correlation changes are most pronounced in central Europe, with maxima  
in southern Germany, Austria, Switzerland, and the Czech Republic.



245 **Figure 5: Climate change impacts on daily PV generation correlations in (a) SSP1-2.6 and (b) SSP5-8.5. Changes are computed relative to 1985-2014 and are displayed as the mean across all 28 models. The dots signify less than 75% model agreement in the sign of the projected changes.**


The large-scale increase in correlations implies that climate change reduces PV balancing potential in Europe in the two considered scenarios. A similar result for wind power is found in Wohland et al. (2017). Moreover, from Fig. 5 we conclude that the negative effects on balancing potential are stronger in the heavily fossil-fueled pathway (SSP5-8.5) than in a sustainable one (SSP1-2.6) indicated by a stronger increase in inter-regional correlations of the PV yields in the former scenario.

250



While this spatial correlation evaluation at the European scale allows investigating the big picture, it involves multiple averaging steps on the individual grid point and is thus convoluted to interpret in greater detail. For a better understanding of the mechanism along with more application-oriented analyses, we therefore conduct case studies for the Iberian and Balkan peninsulas and central Europe (as introduced in Sect. 2.5).

255



260

**Figure 6:** (a) Selected regions for the case study: Iberia ( $10^{\circ}$  W -  $0^{\circ}$ ,  $35 - 42.5^{\circ}$  N; yellow), the Balkans ( $20^{\circ}$  W -  $30^{\circ}$  E,  $35 - 42.5^{\circ}$  N; green) and central Europe ( $5 - 15^{\circ}$  E,  $45 - 50^{\circ}$  N; red). Lower panels: Correlation of deseasonalized PV electricity production (b) between Iberia and the Balkans, (c) between Iberia and central Europe and (d) between the Balkans and central Europe for the historical and the two SSP scenarios based on daily data. The green and blue colors distinguish correlations in summer and winter, respectively. The shapes represent the probability density function of 28 used models. The numbers in the middle indicate the mean correlation coefficient for the specific scenario in each season.

265

Figure 6(a) shows the correlation of daily deseasonalized PV electricity production (excess or deficit from the reference 20-year daily mean, normalized by the reference 20-year standard deviation) between every pair of the three regions for the historical period and the two SSP scenarios. We distinguish between summer and winter months and illustrate the inter-model





270

variability via probability density functions (PDFs, derived from daily time series of PV yields in individual models) of each season's correlation coefficient. The correlation between the Iberian Peninsula and the Balkans is generally low in the historical period (below 0.05 on average across all models, and below 0.4 in absolute terms for any individual model). Daily PV under-production in one region is thus often accompanied by excess production in the other region, implying that, in principle, mutual production buffering on daily time scales is possible.

275


Turning to the future scenarios, average correlations across all models change but little. However, a few models suggest for summer in SSP5-8.5 substantial changes with correlations reaching up to 0.2. The correlation between Iberia and central Europe suggests that there is further potential for PV electricity balancing between these two regions in summer and less so in winter, as indicated in the negative and positive correlations in the respective season. Between the Balkans and central Europe, less difference between summer and winter is visible, although the majority is in the negative range, the correlation in winter is generally lower than in summer.

280

The aggregate assessment using PDFs could mask changes in individual models. We therefore inspect models individually (Fig. 7) and notice that the majority of the models show an increase in correlation from historical to SSPs in both pairs of central Europe with Iberia and the Balkans during both seasons. The average correlation increase in SSP5-8.5 is roughly 0.03 to 0.05 higher than in SSP1-2.6, although in the case of Iberia and central Europe, the winter difference is at most 0.01. More models show correlation decreases in summer than in winter, the models with decreases in SSP1-2.6 also outnumber those in SSP5-8.5.

285

In summary, the case studies support the aggregate assessment as the correlation between the three regions generally increases with forcing. There is only one exception, namely the Iberian Peninsula and the Balkans in winter. While the increase is captured by a large majority of models, detailed power system modeling would be needed to judge the effect of this mild increase in correlation on power system design.



**Figure 7: Change of spatial correlation of daily PV electricity production in SSP1-2.6 (purple) and SSP5-8.5 (orange) for balancing PV electricity of central Europe with Iberia (left) and the Balkans (right) in summer (upper row) and winter (lower row) by alphabetically-sorted models. The dashed lines in the same color as the scenario denote the mean of correlation change.**

290



#### 4 Discussion

Regarding changes in all-sky and clear-sky radiation, as well as surface temperature and cloud fraction, we find CMIP6 based projections to be largely consistent with Wild et al. (2015), who used RCP8.5 data from CMIP5 and looked at trends from 2006 to 2049. In particular, a majority of models from both model generations agree on increasing all-sky radiation in southern Europe and parts of central Europe, while the model agreement is more limited in northern Europe and for clear-sky radiation. Regional climate models, by contrast, often report a widespread decrease in future all-sky radiation in Europe (e.g. Jerez et al. 2015, Bartok et al. 2017), possibly due to a too simple treatment of aerosols (Bartok et al. 2017, Jerez et al., 2021). All mentioned studies use strong forcing scenarios RCP8.5 or RCP4.5. Our CMIP6 based results add to this picture in that we find the increase in all-sky radiation under SSP5-8.5 to result from decreasing cloud cover, which overcompensates the decreasing clear-sky radiation in the wake of a warmer and wetter climate and despite decreasing future aerosol emissions under any SSP. In the much less studied strong mitigation scenario, SSP1-2.6 in the case of CMIP6, we find decreasing cloud cover and increasing clear-sky radiation to act in concert towards increasing all-sky radiation.

With solar radiation being a prime determinant of PV power production, the two quantities show common features in the calculated changes. The effect of the ambient temperature was estimated by Müller et al. (2019) about one order of magnitude smaller, at least in Europe. In fact, the relative change pattern in PV electricity production in SSP5-8.5 is close to the results for RCP8.5 using 23 CMIP5 models in Müller et al. (2019), where they also found an increase in most regions of central to southern Europe. Note that Müller et al. (2019) investigated different periods (2060-2080 compared to 2007-2027) as we do in the present work. Jerez et al. (2015) also confirmed a slightly positive trend in southern Europe based on regional climate models. The PV generation increases in Spain and Germany are also found in Wild et al. (2015) in the RCP8.5 scenario. At the same time, Müller et al. (2019) and Jerez et al. (2015) both reported a decreasing trend of PV yields in relative terms in central to northern Europe.

Our results add two new facets to the discussion concerning the spatio-temporal variability of PV power production. First, we find a tendency that the correlation of daily PV production in spatially distant regions increases, thereby hampering the potential to buffer production variability via regional exchange. Second, we observe a tendency for enhanced seasonal cycles, implying an increased need to buffer such seasonal variability. The changes of correlation coefficients are within 0.4, yet they ought to be taken into account in the future planning of PV production.

#### 5 Conclusions

We show that PV potentials increase in the mitigation scenario SSP1-2.6, suggesting a positive feedback loop where the transition to renewables improves the climatic conditions for renewables. In the mitigation SSP1-2.6 scenario, PV production increases independent of season or region and with a generally high model agreement. Only minor exceptions exist in parts of Scandinavia and Ireland, and in winter also parts of central-eastern Europe and the Iberian Peninsula. Due to clear-sky radiation



and cloud effects acting (in part) against each other, a more complex PV change pattern is found for the strong forcing SSP5-8.5 scenario: summer PV production increases in central and northern Europe but decreases in the south, while in winter this geographical pattern is flipped, in line with prior work by Müller et al. (2019). This complex pattern is largely robust across the CMIP6 models, albeit more uncertain than in SSP1-2.6. An overall higher PV production under SSP1-2.6 conditions contrasts with an increased (decreased) seasonality of PV production in central-northern (southern) Europe under the SSP5-8.5 scenario.

The CMIP6 projections suggest that the spatial correlations of simulated daily PV electricity production in Europe increase towards the end of the 21st century. Consequently, the probability of multiple regions experiencing excess or deficit in PV electricity generation simultaneously increases. We exemplify this general tendency by investigating three regions in greater detail. Deseasonalized daily PV production in the Balkans is largely uncorrelated with production in either the Iberian Peninsula or central Europe, in winter and summer, in present-day and in the future, under either SSP1-2.6 or SSP5-8.5. By contrast, we find for central Europe and the Iberian Peninsula a negative correlation in summer (around -0.15 on average across models) and a positive correlation (around +0.14) in winter under present-day conditions. Except for summer in the SSP1-2.6 scenario, these correlations get less negative / more positive in the future. The finding is robust as more than 75% of the models show this behavior, with 5 out of 28 models showing an increase in correlation of more than 0.1 in summer for the SSP5-8.5 scenario. Such changes in spatial correlations could hamper the effectiveness of future international transmission in balancing PV generation variability.

#### **Data availability**

The CMIP6 data are accessible via the Earth System Grid Federation: <https://esgf-node.llnl.gov/search/cmip6/>.

#### **Author contributions**

XH processed the data, performed the PV simulation, created all figures and wrote the first draft. JW, MW and DF designed the study and regularly provided feedback. All authors analyzed the results and wrote the manuscript.

#### **Competing interests**

The authors declare that they have no conflict of interest.

#### **Acknowledgements**

We acknowledge the World Climate Research Program which, through its Working Group on Coupled Modelling, coordinated



and promoted CMIP6. We thank the climate modeling groups for producing and making available their model output, the Earth System Grid Federation (ESGF) for archiving the data and providing access, and the multiple funding agencies that support CMIP6 and ESGF. XH is funded through the European Commission project EuroGEO e-shape (grant agreement No 820852). JW is funded through an ETH Postdoctoral Fellowship and acknowledges support from the ETH foundation and the Uniscientia foundation. MW and DF acknowledge funding from the Swiss National Science Foundation Grant No. 200020\_188601.

## References

- 355 Bartok, B., Wild, M., Folini, D., Lüthi, D., Kotlarski, S., Schär, C., Vautard, R., Jerez, S., and Imecs, Z.: Projected changes in surface solar radiation in CMIP5 global climate models and in EURO-CORDEX regional climate models for Europe. *Clim. Dyn.*, 49, 2665–2683, doi: 10.1007/s00382-016-3471-2, 2017.
- Bauer, N., Calvin, K., Emmerling, J., Fricko, O., Fujimori, S., Hilaire, J., Eom, J., Krey, V., Kriegler, E., Mouratiadou, I., Sytze de Boer, H., van den Berg, M., Carrara, S., Daioglou, V., Drouet, L., Edmonds, J. E., Gernaat, D., Havlik, P., Johnson, N., Klein, D., Kyle, P., Marangoni, G., Masui, T., Pietzcker, R. C., Strubegger, M., Wise, M., Riahi, K., and van Vuuren, D. P.: Shared Socio-Economic Pathways of the Energy Sector – Quantifying the Narratives, *Global Environmental Change*, 42, 316–330, doi: 10.1016/j.gloenvcha.2016.07.006, 2017.
- 360 Bloomfield, H. C., Gonzalez, P. L. M., Lundquist, J. K., Stoop, L. P., Browell, J., Dargaville, R., De Felice, M., Gruber, K., Hilbers, A., Kies, A., Panteli, M., Thornton, H. E., Wohland, J., Zeyringer, M., and Brayshaw, D. J.: The Importance of Weather and Climate to Energy Systems: A Workshop on Next Generation Challenges in Energy–Climate Modeling. *B. Am. Meteorol. Soc.*, 102, 1, E159-E167, doi: 10.1175/BAMS-D-20-0256.1, 2021.
- 365 Bremen L.V.: Large-Scale Variability of Weather Dependent Renewable Energy Sources. In: Troccoli A. (eds) Management of Weather and Climate Risk in the Energy Industry. NATO Science for Peace and Security Series C: Environmental Security. Springer, Dordrecht. doi: 10.1007/978-90-481-3692-6\_13, 2010.
- 370 Creutzig, F., Agoston, P., Goldschmidt, J.C., Luderer, G., Nemet, G., Pietzcker, R.C.: The underestimated potential of solar energy to mitigate climate change. *Nat. Energy*, 2, 17140, doi: 10.1038/nenergy.2017.140, 2017.
- Crook, J. A., Jones, L. A., Forster, P. M., and Crook, R.: Climate change impacts on future photovoltaic and concentrated solar power energy output, *Energ. Environ. Sci.*, 4, 3101–3109, doi: 10.1039/c1ee01495a, 2011.
- EU: Communication from the Commission to the European Parliament, the European Council, the Council, the European Economic and Social Committee and the Committee of the Regions (COM(2019) 640 final), [https://eur-lex.europa.eu/resource.html?uri=cellar:b828d165-1c22-11ea-8c1f-01aa75ed71a1.0002.02/DOC\\_1&format=PDF](https://eur-lex.europa.eu/resource.html?uri=cellar:b828d165-1c22-11ea-8c1f-01aa75ed71a1.0002.02/DOC_1&format=PDF), last



access: 23 June 2021, 2019.

380 Eyring, V., Bony, S., Meehl, G. A., Senior, C. A., Stevens, B., Stouffer, R. J., and Taylor, K. E.: Overview of the Coupled Model Intercomparison Project Phase 6 (CMIP6) experimental design and organization, *Geosci. Model Dev.*, 9, 1937–1958, doi: 10.5194/gmd-9-1937-2016, 2016.

Gaetani, M., Huld, T., Vignati, E., Monforti-Ferrario, F., Dosio, A., and Raes, F.: The near future availability of photovoltaic energy in Europe and Africa in climate-aerosol modeling experiments, *Renewable and Sustainable Energy Reviews*, 38, 706–716, doi: 10.1016/j.rser.2014.07.041, 2014.

385 Gidden, M. J., Riahi, K., Smith, S. J., Fujimori, S., Luderer, G., Kriegler, E., van Vuuren, D. P., van den Berg, M., Feng, L., Klein, D., Calvin, K., Doelman, J. C., Frank, S., Fricko, O., Harmsen, M., Hasegawa, T., Havlik, P., Hilaire, J., Hoesly, R., Horing, J., Popp, A., Stehfest, E., and Takahashi, K.: Global emissions pathways under different socioeconomic scenarios for use in CMIP6: a dataset of harmonized emissions trajectories through the end of the century, *Geosci. Model Dev.*, 12, 1443–1475, doi: 10.5194/gmd-12-1443-2019, 2019.

390 Grams, C.M., R. Beerli, S. Pfenninger, I. Staffell, and H. Wernli: Balancing Europe’s wind power output through spatial deployment informed by weather regimes, *Nat. Clim. Change*, 7 (8), 557–562, doi:10.1038/nclimate3338, 2017.

Gutiérrez, C., Somot, S., Nabat, P., Mallet, M., Corre, L., van Meijgaard, E., Perpiñán, O., and Gaertner, M. Á.: Future evolution of surface solar radiation and photovoltaic potential in Europe: investigating the role of aerosols, *Environ. Res. Lett.*, 15, 34035, doi: 10.1088/1748-9326/ab6666, 2020.

395 Heide, D., von Bremen, L., Greiner, M., Hoffmann, C., Speckmann, M., and Bofinger, S.: Seasonal optimal mix of wind and solar power in a future, highly renewable Europe, *Renew. Energ.*, 35, 2483–2489, doi: 10.1016/j.renene.2010.03.012, 2010.

IPCC: *Climate Change 2013: The Physical Science Basis. Contribution of Working Group I to the Fifth Assessment Report of the Intergovernmental Panel on Climate Change* [Stocker, T.F., D. Qin, G.-K. Plattner, M. Tignor, S.K. Allen, J. Boschung, A. Nauels, Y. Xia, V. Bex and P.M. Midgley (eds.)], Cambridge University Press, Cambridge, United Kingdom and New York, NY, USA, 2013.

400 IRENA: *Future of Solar Photovoltaic: Deployment, investment, technology, grid integration and socio-economic aspects (A Global Energy Transformation: paper)*, International Renewable Energy Agency, Abu Dhabi, 2019.

IRENA: *Trends in Renewable Energy*, <http://resourceirena.irena.org/gateway/dashboard/?topic=4&subTopic=16>, last access: 24 March 2021, 2020.

Jacob, D., Petersen, J., Eggert, B. et al. EURO-CORDEX: new high-resolution climate change projections for European impact



- 405 research. *Reg. Environ. Change*, 14, 563–578, doi: 10.1007/s10113-013-0499-2, 2014.
- Jacobson, M. Z. and Jadhav, V.: World estimates of PV optimal tilt angles and ratios of sunlight incident upon tilted and tracked PV panels relative to horizontal panels, *Sol. Energy*, 169, 55–66, doi: 10.1016/j.solener.2018.04.030, 2018.
- Jerez, S., Palacios-Peña, L., Gutiérrez, C., Jiménez-Guerrero, P., López-Romero, J. M., Pravia-Sarabia, E., and Montávez, J. P.: Sensitivity of surface solar radiation to aerosol–radiation and aerosol–cloud interactions over Europe in WRFv3.6.1 climatic runs with fully interactive aerosols, *Geosci. Model Dev.*, 14, 1533–1551, doi: 10.5194/gmd-14-1533-2021, 2021.
- 410 Jerez, S., Tobin, I., Vautard, R., Montávez, J. P., López-Romero, J. M., Thais, F., Bartok, B., Christensen, O. B., Colette, A., Déqué, M., Nikulin, G., Kotlarski, S., van Meijgaard, E., Teichmann, C., and Wild, M.: The impact of climate change on photovoltaic power generation in Europe, *Nat. Commun.*, 6, 10 014, doi: 10.1038/ncomms10014, 2015.
- Kittner, N., Lill, F., Kammen, D.M.: Energy storage deployment and innovation for the clean energy transition. *Nat. Energy*, 415 2, 17125. doi: 10.1038/nenergy.2017.125, 2017
- Müller, J., Folini, D., Wild, M., and Pfenninger, S.: CMIP-5 models project photovoltaics are a no-regrets investment in Europe irrespective of climate change, *Energy*, 171, 135–148, doi: 10.1016/j.energy.2018.12.139, 2019.
- Müller, W. A., Jungclaus, J. H., Mauritsen, T., Baehr, J., Bittner, M., Budich, R., Bunzel, F., Esch, M., Ghosh, R., Haak, H., Ilyina, T., Kleine, T., Kornbluh, L., Li, H., Modali, K., Notz, D., Pohlmann, H., Roeckner, E., Stemmler, I., Tian, F., and Marotzke, J.: A Higher-resolution Version of the Max Planck Institute Earth System Model (MPI-ESM1.2-HR), *J. Adv. Model. Earth Sy.*, 10, 1383–1413, doi: 10.1029/2017MS001217, 2018.
- 420 O’Neill, B. C., Tebaldi, C., van Vuuren, D. P., Eyring, V., Friedlingstein, P., Hurtt, G., Knutti, R., Kriegler, E., Lamarque, J.-F., Lowe, J., Meehl, G. A., Moss, R., Riahi, K., and Sanderson, B. M.: The Scenario Model Intercomparison Project (ScenarioMIP) for CMIP6, *Geosci. Model Dev.*, 9, 3461–3482, doi: 10.5194/gmd-9-3461-2016, 2016.
- 425 Panagea, I. S., Tsanis, I. K., Koutroulis, A. G., and Grillakis, M. G.: Climate Change Impact on Photovoltaic Energy Output: The Case of Greece, *Adv. Meteorol.*, 2014, 1–11, doi: 10.1155/2014/264506, 2014.
- Pfenninger, S. and Staffell, I.: Long-term patterns of European PV output using 30 years of validated hourly reanalysis and satellite data, *Energy*, 114, 1251–1265, doi: 10.1016/j.energy.2016.08.060, 2016.
- Ridley, B., Boland, J., and Lauret, P.: Modelling of diffuse solar fraction with multiple predictors. *Renew. Energy*, 35, 478–483, doi:10.1016/j.renene.2009.07.018, 2010.
- 430 Rodríguez, R.A., Becker, S., Andresen, G.B., Heide, D., Greiner, M.: Transmission needs across a fully renewable European



- power system. *Renew. Energy*, 63, 467–476. doi: 10.1016/j.renene.2013.10.005, 2014.
- Séférian, R., Nabat, P., Michou, M., Saint-Martin, D., Voldoire, A., Colin, J., Decharme, B., Delire, C., Berthet, S., Chevallier, M., Sénési, S., Franchisteguy, L., Vial, J., Mallet, M., Joetzjer, E., Geoffroy, O., Guérémy, J.-F., Moine, M.-P., Msadek, R., Ribes, A., Rocher, M., Roehrig, R., Salas-y Mélia, D., Sanchez, E., Terray, L., Valcke, S., Waldman, R., Aumont, O., Bopp, L., Deshayes, J., Éthé, C., and Madec, G.: Evaluation of CNRM Earth System Model, CNRM-ESM2-1: Role of Earth System Processes in Present-Day and Future Climate, *J. Adv. Model. Earth Sy.*, 11, 4182–4227, doi: 10.1029/2019MS001791, 2019.
- Taylor, K.E., Stouffer, R.J. and Meehl, G.A.: An Overview of Cmp5 and the Experiment Design. *B. Am. Meteorol. Soc.*, 93(4): 485–498, doi: 10.1175/BAMS-D-11-00094.1, 2012.
- 440 Tröndle, T., Pfenninger, S., Lilliestam, J.: Home-made or imported: On the possibility for renewable electricity autarky on all scales in Europe. *Energy Strateg. Rev.*, 26, 100388, doi: 10.1016/j.esr.2019.100388, 2019.
- UNFCCC: Adoption of the Paris Agreement, Decision1 /CP.21 of FCCC/CP/2015/10/Add.1, <http://unfccc.int/resource/docs/2015/cop21/eng/10a01.pdf>, 2015.
- van der Wiel, K., Bloomfield, H.C., Lee, R.W., Stoop, L.P., Blackport, R., Screen, J.A., Selten, F.M.: The influence of weather regimes on European renewable energy production and demand, *Environ. Res. Lett.*, 14, 094010, doi: 10.1088/1748-9326/ab38d3, 2019.
- Wild, M., Folini, D., Henschel, F., Fischer, N., and Müller, B.: Projections of long-term changes in solar radiation based on CMIP5 climate models and their influence on energy yields of photovoltaic systems, *Sol. Energy*, 116, 12–24, doi: 10.1016/j.solener.2015.03.039, 2015.
- 450 Wohland, J., Reyers, M., Weber, J., and Witthaut, D.: More homogeneous wind conditions under strong climate change decrease the potential for inter-state balancing of electricity in Europe, *Earth Syst. Dynam.*, 8, 1047–1060, doi: 10.5194/esd-8-1047-2017, 2017.